



NOTE:
ALUMINUM/GLASS/WINDOW CONTRACTOR SHALL SUBMIT DOCUMENTATION TO THE G.C. FOR SUBMISSION TO PERMIT AUTHORITIES CERTIFYING OPERATING WINDOWS AND METHOD OF INSTALLATION WILL MEET SBC WIND LOAD REQUIREMENTS OF 110 MPH. FIXED GLASS/ALUMINUM TUBE FRAMING AND METHOD OF INSTALLATION SHALL BE DESIGNED BY AN ENGINEER REGISTERED IN THE STATE OF FLORIDA CERTIFYING THAT COMPONENT ASSY AND INSTALLATION WITH MEET SAME SBC AND STATE OF FLORIDA REQUIREMENTS. THE AGREEMENT TO THE ABOVE REQUIREMENTS SHALL BE IMPLIED BY THE SUBMISSION OF BIDS TO THE GENERAL CONTRACTOR.

THIS BUILDING ADDITION HAS BEEN DESIGNED TO MEET 110 MPH WIND SPEED CRITERIA AS SET FORTH BY THE 1997 SBCCI STANDARD BUILDING CODE.

ADDITIONS TO THE
G. KELLY FAMILY RESIDENCE
PINE RIDGE
73 RIDGE DRIVE

FLOOR PLAN ADDITIONS

3/27 & 2/9/23

1/4" = 1'-0"